



#### NOTES:

1. FOOTPATHS TO HAVE A 2.5% TYPICAL CROSSFALL TOWARDS THE KERB - THIS IS A 30mm FALL OVER A 1.2m WIDE FOOTPATH.
2. REFER TO CIV.11 FOR JOINT DETAIL.
3. CONCRETE EDGES SHALL BE FINISHED WITH AN EDGING TOOL.
4. CONCRETE SHALL HAVE A 28 DAY STRENGTH OF 25MPa MINIMUM.
5. CONCRETE SHALL BE PLACED WITH A MAXIMUM SLUMP OF 80mm.
6. MINIMUM CONCRETE COVER TO BE 40mm UNLESS NOTED OTHERWISE.
7. THE COUNCIL ENGINEER REQUIRES 24 HOURS NOTICE PRIOR TO POURING OF CONCRETE TO INSPECT THE FORMWORK. NO CONCRETE SHALL BE POURED UNTIL THE EXCAVATION AND FORMWORK HAVE BEEN INSPECTED.
8. ALL DIMENSIONS IN MILLIMETRES UNLESS NOTED OTHERWISE.

COPYRIGHT © 2011 City of Ryde - ALL RIGHTS RESERVED  
 No part of this document shall be modified or reproduced without written permission.  
 Go to [www.ryde.nsw.gov.au/disclaimer](http://www.ryde.nsw.gov.au/disclaimer) to view the Standard Drawings Disclaimer