



**NOTES**

1. EXACT LOCATION OF NEW SUBSOIL DRAIN TO CONNECT AND / OR ALIGN WITH EXISTING SYSTEM TO BE DETERMINED ON SITE.
2. THE MINIMUM GRADE OF THE LINE TO BE 1 IN 200. THE GRADE SHALL FALL CONTINUOUSLY TO PREVENT SILTING UP AND BLOCKAGES.
3. SELECTED GRANULAR MATERIAL BACKFILL SHALL BE PLACED TO FILL ALL EXCAVATED VOIDS. (REFER TO AS 3725-2007)
4. A MAXIMUM FILTER AGGREGATE SIZE OF 10mm TO BE USED TO AVOID PUNCTURING THE PIPE.
5. ALL WORKS AND MATERIALS ACCORDING TO A.S. 3500.3-2003 SECTION 6.
6. A MINIMUM 50mm LAYER OF FILTER MATERIAL TO BE PLACED IN THE TRENCH TO PROVIDE A DRAINAGE PATH UNDERNEATH THE PLASTIC PIPE.
7. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS NOTED OTHERWISE. (U.N.O.)

COPYRIGHT © 2011 City of Ryde - ALL RIGHTS RESERVED  
No part of this document shall be modified or reproduced without written permission.  
Go to [www.ryde.nsw.gov.au/disclaimer](http://www.ryde.nsw.gov.au/disclaimer) to view the Standard Drawings Disclaimer



STANDARD DRAWING  
**STANDARD  
SUB-SOIL DRAINAGE  
DETAILS**

APPROVED VP DESIGN MANAGER	DATE 23/06/16
DRAWING NUMBER <b>SWD.2</b>	REVISION <b>C</b>